



Energy Feasibility Study Report

for

Summer Gardens

1470 Summer Street, Halifax, NS



August 10th, 2023

August 10th, 2023

Summer Gardens

1470 Summer Street
Halifax, NS

Attention: **Condominium Board**

Re: **Energy Feasibility Study Report**

To Whom it May Concern,

PMC Energy Ltd. is pleased to provide you with the following Draft Energy Feasibility Study Report and associated proposal outlining the budgets, savings, and benefits of various Energy Efficiency and Conservation Measures at 1470 Summer Street, Halifax, NS.

The purpose of this study is to identify and analyze feasible energy efficiency and conservation opportunities resulting in energy savings for the facility. This report will serve two purposes; submission to Efficiency NS for review and approval of the estimated incentives through their various incentive programs, and as a guide for pursuing energy projects to improve building performance and reduce its carbon footprint.

The implementation of the Energy Conservation and Efficiency Measures (ECMs) outlined in this report is recommended. The comprehensive energy measures present the best opportunity to reduce the facility's operating costs and environmental footprint. It should be noted that the ECM costs shown in this report are a mix of budgetary and true costs for PMC to complete the work in a turn-key manner.

If you have any questions or require clarifications regarding any specific items addressed in this proposal, please feel free to contact me at your convenience.

Kind Regards,



Scott Hue, B.Eng., CEM
Director of Energy
scott@pmcenergy.ca

TABLE OF CONTENTS

1. Building and Systems Description.....	3
1.1 General Description of Building	3
1.2 Occupancy Summary	3
1.3 Common Area Mechanical Equipment	4
1.4 Lighting Systems	5
1.5 Building Automation System (BAS)	5
2. Energy Summary.....	6
2.1 Historical Utility Consumption and Demand – Baseline Data	6
2.2 Calculated Annual Energy Distribution	6
2.3 Regression Analysis (RETScreen Expert)	7
3. Energy Efficiency and Conservation Measures	8
3.1 ECM-1: New Building Automation System, Repairs, Recommissioning	8
3.1.1 Existing Conditions	8
3.1.2 Proposed Measure	8
3.1.3 Measure Summary	10
3.2 ECM-1b: Heat Pump Retrofit for Penthouse DOAS.....	11
3.2.1 Existing Conditions	11
3.2.2 Proposed Measure	11
3.2.3 Measure Summary	11
3.3 ECM-1c: Solar Air Preheat for Penthouse DOAS	12
3.3.1 Existing Conditions	12
3.3.2 Proposed Measure	12
3.3.3 Measure Summary	13
3.4 ECM-2: Parkade Level Heat Pump Retrofit with VRV	13
3.4.1 Existing Conditions	13
3.4.2 Measure Summary	13
3.5 ECM-3 – DCW Booster Pump Replacement with High Efficiency Variable Speed System.....	14
3.5.1 Existing Conditions	14
3.5.2 Proposed Measure	14

- 3.5.3 Measure Summary 14
- 3.6 ECM-4: Replace DHW Tank with Heat Pumps (Qty.2) 15
 - 3.6.1 Existing Conditions 15
 - 3.6.2 Proposed Measure 15
 - 3.6.3 Measure Summary 16
- 3.7 ECM-5 – Rooftop Solar PV Option..... 16
 - 3.7.1 Existing Conditions 16
 - 3.7.2 Proposed Measure 16
 - 3.7.3 Measure Summary 17
- 3.8 Additional Opportunities & Recommendations..... 18
- 3.9 ECM Summary Table..... 20

LIST OF TABLES AND FIGURES

- Table 1 - Equipment List..... 4
- Table 2 – Lighting Summary 5
- Table 3 - Energy Calculation vs. Utility Baseline 6
- Figure 1 - Calculated Annual Energy Distribution..... 6
- Figure 2 - 2021/2022 Regression Analysis 7
- Figure 3 - HDD Regression Analysis Graph – Baseline Predicted vs Actual Consumption (kWh’s)..... 7
- Figure 4 - Example Solar AIR Preheat System..... 12
- Figure 5 - Example Winter Vestibule 18

LIST OF APPENDICES

- APPENDIX A – Utility Baseline
- APPENDIX B – Energy Calculations

1. BUILDING AND SYSTEMS DESCRIPTION

1.1 General Description of Building

Summer Gardens located in the heart of downtown Halifax with lovely private property surrounding. There are 118 residential suites, through the focus of this report are the common area systems and areas within the facility. The facility includes an indoor year-round pool/hot tub/sauna and exercise facility, underground parking, guest parking, and common room with kitchen and outside patio for meetings and parties.

Summer Garden wished to explore opportunities associated with the building automation, space heating (and cooling), ventilation as well as pool heating and dehumidification to create a more efficient facility with reduced operating costs and improved system performance. A strong interest was also expressed in the implementation of demand management system, with the intent to be able to minimize peak loads in real time.

1.2 Occupancy Summary

PMC's audit scope included a detailed audit and review of all the common area systems. Most areas are currently being operated 24/7/365, though there is an opportunity to reduce run-hours or equipment capacities on targeted equipment, such the dedicated outdoor air system (DOAS) located in the penthouse.

1.3 Common Area Mechanical Equipment

The mechanical systems serving all the facilities common areas is summarized in the table below.

Table 1 - Equipment List

Tag	Description of Equipment	Qty	Area Served
SF-1 (New)	Supply Fan Grid	1	New SF Array
DH-1	Duct Heater 162kW	1	DOAS (SF-1 & EF-1)
EF-1	Exhaust Fan (DOAS)	1	Bathrooms, Kitchen Range, Dryers
EF-2	Dryer Exhaust Fan	1	Dryer Exhaust Riser 26/16
EF-3	Dryer Exhaust Fan	1	Dryer Exhaust Riser 34/12
RE-1	Roof Exhauster-1	1	Smoke Extractor from Supply Duct
RE-2	Roof Exhauster-2	1	General Penthouse Exhaust
RE-3	Roof Exhauster-3	1	Elevator Machine Room
HUH-1	Elec Unit Heater	1	General Penthouse Area
HUH-2	Elec Unit Heater	1	Elevator Room
CUH-1	Cabinet Unit Heater - Sidewall	1	Front Entrance Vestibule
CUH-2	Cabinet Unit Heater - Recessed Ceiling	2	Front Entrance Vestibule
CUH-3	Small Recessed Wall Heater in Mail Room	1	Ground Floor Mail Room
CUH-4	Electric Wall Heater	1	Rear Delivery Area
CUH-5	Cabinet Unit Heater - Sidewall	1	Rear Vestibule
EF-12	In-Line EF	1	Lounge and Mail Room
MS-1	Mini-Split	1	Common Area / Lobby
MS-2	Mini-Split	1	Lounge
CUH-6	Cabinet Unit Heater - Sidewall	1	Stairwell to Pool Area
Portable Dehum	Portable Dehum Running in Pool Area	2	Stairwell to Pool Area
CUH-7	Electric Wall Heater	2	Men's & Women's Washrooms by Pool
SH's	Sauna Heaters	3	Sauna
P-1	Pool Pump	1	Pool
PH-1	Pool Electric Heater	1	Pool
AH-1	Air Handling Unit (HHU-1-2)	1	Maintenance, Elevator Lobby, Men's and Ladies Change Rm, Gym
Duct Heater-1	Duct Heater for AH-1	1	Maintenance, Elevator Lobby, Men's and Ladies Change Rm, Gym
EF-5	Exhaust Fan	1	Storage Room, Gym, Washrooms, Sauna, Maintenance Room
AH-2	Air Handling Unit	1	Parking Level - Storage Lockers
AH-3	Air Handling Unit	1	Parking Level - Stairwell Pressurization
TF-1	Wall Mounted Transfer Fan	1	Air Pushed Into Pool Mech Room
TF-2	Wall Mounted Transfer Fan	1	Exhaust from DCM Pump Room (Pulled from Storage Room)
EF-4	Garbage Room EF	1	Garbage Room EF
EF-6,7	Parkade CO/NO EF's	2	Parking Level - Car Wash Area
EF's 8,9,10	Parkade CO/NO EF's	3	Parkade
EF- 11	Parkade Vault EF	1	Elec Vault
Dectron	Dry-O-Tron	1	Pool Room
Dectron Duct Heater	Duct Heater for Dectron	1	Pool Deck
Dehum	Small Dehum Unit in Storage Area	1	Storage Area - Parkade Level
BP-1	Booster Pumps	2	Booster Pumps
SP-1	Sump Pumps	?	Parkade
DHT	DHW Tank	1	Janitor Room
DHT	DHW Tank (Car Wash)	1	Wash Bay
SM	Snowmelt Boiler	1	Parkade Ramp
Burner	Burner	1	Ramp
P-2	Pump	1	Boiler
Jacuzzi	Jacuzzi	1	Pool Area

1.4 Lighting Systems

Most of the interior and exterior lights at Summer Gardens have already been upgraded to LED fixtures. There is a variety of lighting fixture styles and lamp types throughout the building. The timer for the exterior lights was missing its pins and lights appear to be operating 24/7 vs just at night when required. Occupancy sensors could be considered in some areas to provide additional energy savings.

A summary of lighting fixtures can be viewed below in Table 2.

Table 2 – Lighting Summary

Area / Room / Zone	Type	Fixture Quantity	Watts per Fixture	Schedule (hr/year)	kWh/year
	Phillips 5W 4000K PL-S	164	5	8,736	7,164
Front + Rear Entrance Canopy	Phillips 13W PAR38 + E26 Socket	2	13	4,368	114
Operations Office	Philips 9.5T8/48-4000K IF + 2L Vol. Parabolic	1	21	1,560	33
Lobby + Elevator Tray Ceiling	Philips 9.5T8/48-4000K IF	60	21	8,736	11,007
Mail Box Alcove	Philips 9.5T8/48-4000K IF	2	21	8,736	367
Rear Service Hall	Philips 13T8/48-4000K HO IF + 1L Vol. Parabolic	2	16	8,736	280
Rear Exit Hallway	Philips 9.5T8/48-4000K IF + 1L Vol. Parabolic	3	13	8,736	341
Suite Door Bulkheads	Philips 9.5T8/48-4000K IF	122	13	8,736	13,855
Parkade Main Hallway	Philips 9.5T8/48-5000K IF + 2L Vol. Parabolic	6	21	8,736	1,101
Parkade Air Locks	Philips 9.5T8/48-5000K IF	4	21	8,736	734
Pool Tray Ceiling	Philips 9.5T8/48-5000K IF	20	21	8,736	3,669
Pool Change + Washrooms	Philips 9.5T8/48-5000K IF	8	21	8,736	1,468
Pool	LED-8008M57-MHBC (PWB1KN5C)	4	50	8,736	1,747
Exercise Room	Philips 9.5T8/48-5000K IF + 2L Vol. Parabolic	3	21	8,736	550
Parkade	Philips 9.5T8/48-5000K IF	58	21	8,736	10,640
Vehicle Wash Bay	Philips 15W Daylight A19 + E26 Socket	4	15	260	16
Recycle & Refuse Rooms	Philips 9.5T8/48-5000K IF	5	21	2,080	218
Utility + Rear Hallways	Philips 9.5T8/48-5000K IF	5	21	8,736	917
Parkade Service Stairwell	TuroLight DL-EC/4F/35W/50/120-347V/D	2	3	8,736	52
Tenant Storage Lockers	TuroLight DL-EC/4F/35W/50/120-347V/D	26	3	8,736	681
Stairwells + Alcove	TuroLight DL-EC/4F/35W/50/120-347V/D	45	3	8,736	1,179
Mechanical Stairwell	TuroLight DL-EC/4F/35W/50/120-347V/D	2	3	8,736	52
Mechanical Stairwell	TuroLight DL-EC/4F/35W/50/120-347V/D	1	3	8,736	26
Mechanical Penthouse Fixtures	Ecolux F34CW-RS-WM-ECO	16	34	780	424
Totals		565	405	8635	56,636

1.5 Building Automation System (BAS)

There is very little in place in terms of a building automation system aside from a Honeywell controller currently in place for the Penthouse DOAS system. Control and scheduling of most other equipment is achieved through local thermostats and in some cases timeclocks.

2. ENERGY SUMMARY

2.1 Historical Utility Consumption and Demand – Baseline Data

Summer Garden has two electrical meters serving the common area systems. Consumption and demand summary tables were assembled from historical data from 2020 and can be found in Appendix A. A summary of the annual consumption and demand is shown below for reference.

2020 Baseline Utility Data

Baseline Annual ELECTRICAL Consumption (kWh)	937,880
Baseline Annual ELECTRICAL Demand (kW)	2,324
Baseline TOTAL Energy Costs (Using Current Rates)	\$138,519.94
Baseline Energy Cost per Square Foot (Using Current Rates)	\$5.861

The peak electrical load of the facility occurs during the winter months. January of 2020 recorded a peak demand of 275.4 kW. The major contributors to the peak demand are the electric coils associated with the Penthouse DOAS unit and AH-1 in the Parkade Level.

2.2 Calculated Annual Energy Distribution

The annual energy consumption and annual demand for each system (or piece of equipment) was calculated (refer to Appendix B – Energy Calculations) and the summary table is shown below.




Figure 1 - Calculated Annual Energy Distribution

The calculated figures shown above were then compared to the established utility baseline data provided in Appendix A. As shown below the calculated values are within 10% of the actual utility baseline.

Table 3 - Energy Calculation vs. Utility Baseline

	Consumption (kWh)	(Demand kW)
Calculated Totals:	998,015.02	2,466.32
Proposed Baseline (2020):	937,880.00	2,323.90
Percent of Actual:	106.41%	106.13%

2.3 Regression Analysis (RETScreen Expert)

RETScreen Expert was used to analyze the baseline consumption data and to develop a model which allows us to accurately predict the future energy consumption of the building under the scenario where no upgrades are completed. The model uses hourly weather data which will ensure that future energy consumptions are automatically adjusted for weather conditions.

As seen in Figure 3 below there is a strong correlation between heating degree days (balance point 16°C) and consumption which returned an R² value of 0.9811. These balance points have been used in the calculations through this report.




Figure 3 - HDD Regression Analysis Graph – Baseline Predicted vs Actual Consumption (kWh’s)

Given these results; PMC will use the developed RETScreen model and regression formulas to adjust future energy consumption as compared to the baseline.

3. ENERGY EFFICIENCY AND CONSERVATION MEASURES

PMC has completed a detailed review of the site conditions and equipment and has identified the following list of investigated Energy Efficiency and Conservation Measures (ECM's).

3.1 ECM-1: New Building Automation System, Repairs, Recommissioning

3.1.1 Existing Conditions

The existing Dedicated Outdoor Air Unit (DOAS) unit includes a passive heat recovery coil that is approximately 60% efficient. There is also a 162kW electric coil providing additional heat to the supply to ensure a neutral air temperature is delivered to the hallways. This creates a high electric demand when all stages are active. The DOAS unit's energy consumption is more than 30% of the total energy consumption associated with the two meters.

3.1.2 Proposed Measure

PMC completed a detailed inspection of the current DOAS unit and its associated components. We noted failed actuators and worn-out dampers as well as opportunities to refine the control and sequencing on the DOAS through the implementation of a modern control system. The scope below is comprehensive and provisions have been made to provide connection and control over all major energy consumers serving the common areas. Scope details include;

- Supply & install a BACnet IP Building Automation System (BAS), complete with controls wiring, connections and web-based graphical interface.
- Supply & install new controllers and sensors for equipment located in the P1 Parkade Level including pool equipment (i.e., pumps, heaters), Dectron DH unit, new VRV system proposed in ECM-2, AH-1, AH-2, EF-4, EF-5 and new domestic booster pump set proposed in ECM-3.
 - Supply and install new ultra-low leakage insulated dampers to replace the seized dampers associated with the Dectron unit.
 - Supply and install new SCRs on the Dectron duct heater as well as the pool heater.
- Supply & install new controllers and sensors for equipment located in the Penthouse including the DOAS system (SF-1, EF-1) as well as dryer exhaust fans, penthouse and elevator room exhaust fans and heaters.
 - Supply and install new ultra-low leakage insulated dampers to replace the intake damper in the elevator machine room and the intake dampers associated with RE-2.
 - Supply and install new isolation dampers for EF-2, and EF-3 to reduce stack effect when these fans are commanded OFF at night.
 - Supply and install new isolation dampers on the kitchen range duct risers to provide a means of reducing airflow of the DOAS at night.
 - Provide an air balance of the DOAS. Ensure air balance and recommissioning results in two balanced modes of operation including daytime off-peak operation.
- Supply & install new controllers and sensors for equipment located on the Ground Floor level including the cabinet heaters in the front and rear entrances.

- Supply and install Smart Power Meters for the metering of the two power feeds associated with the meter sets examined in the baseline. The power meters will integrate into the BAS server for monitoring and recording purposes. The overall intent is to measure and meter the demand (kW) at a building level and then utilize the controls system to reduce and minimize the overall peak levels by staging, controlling, measuring, and verifying the high energy consumers. A draft list of recommended loads and strategies include;
 - Shut-Off Dryer EF-2, EF-3
 - Night Mode on DOAS - Reduced Airflow
 - Supply Air Temperature (SAT) Reset of DOAS
 - SAT and/or Setpoint (SP's) Resets of AH-1
 - Shut-Off AH-2
 - Disable RE-2 (General Penthouse Exhaust)
 - Disable HUH-1, HUH-2, CUH-1, CUH-2's, CHU-5
 - Reset SPs for New Gym and Pool Area Wall Mount Unit
 - Disable Pool Pump
 - Disable Pool Heater
 - Disable Dectron Pool Unit (or reset SAT's) and Associated Duct Heater
 - Building Automation System (BAS) with Graphics, Alarm Reporting, and Remote Connection Capabilities, as well as Maintenance Manual, Labels, Panel Points Lists, and Training is included.
 - Internet connections will be required for building automation systems. PMC to work with owners for requirements and access.
 - PMC to provide remote alarms that will be sent to the building representative for the equipment controlled in this proposal.
 - Please note that the car charging systems being contemplated do not appear to be capable of communicating with the proposed building automation system; however, further investigation is currently underway.
 - As this is an existing building access to equipment can be difficult. Therefore, coring, firestopping, minimal drywall demolition, and painting may be required. PMC has not included these costs in the proposal. PMC to coordinate and work with owners for accommodations and gathering proposals for such work as required.
-

3.1.3 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback.

ECM-1: New Building Automation System, Repairs, Recommissioning			
Measure Description	Supply and install a complete new building automation system to provide control and sequences of the major energy users in the Penthouse, Ground Floor and P1 Levels. To also include new dampers, recommissioning and air balancing on the DOAS system.		
Impact on System Performance	Occupant comfort will be improved slightly via new sequences and system performance.		
Impact on Operations and Maintenance	Minor and incremental improvements to the existing systems and components so relatively little change to operations and maintenance tasks and associated costs.		
Energy and Financial Summary			
Total Project Cost:	\$159,660.00	Total Utility Bill Savings in Dollars:	\$14,825.80
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$12,349.86	+ Additional Annual Savings (Maint):	\$0.00
= Total Investment:	\$147,310.14	= Total Annual Savings Estimate:	\$14,825.80
Annual Consumption Savings (kWh's):	123,498.62	Simple Payback:	9.9
Annual Demand Savings (kW):	106.88	Useful Life (years):	20
		Return on Investment:	5.06%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

Notes:

- Simple payback and ROI are based on fixed rates and do not account for NS Power's annual rate increases.

3.2 ECM-1b: Heat Pump Retrofit for Penthouse DOAS

3.2.1 Existing Conditions

The existing DOAS unit includes a passive heat recovery coil that is approximately 60% efficient. There is also a 162kW electric coil providing additional heat to the supply to ensure a neutral air temperature is delivered to the hallways. This creates a high electric demand when all stages are active and is responsible for a larger portion of building energy consumption. New heat technology and equipment options are becoming more widely available.

3.2.2 Proposed Measure

PMC explored several options during our investigations of this measure. The manufacturer AIR has proposed a retrofit kit that utilizes the refrigeration cycle to heat or cool the ventilation air by turning the exhaust air into a heat sink or source. In the winter exhaust air can provide COPs of greater than 5 because exhaust temperatures are much higher than outdoor ambient conditions.

3.2.3 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback.

ECM-1b: Heat Pump Retrofit of Penthouse DOAS (or New Combined ERV, Heat Pump)			
Measure Description	Heat Pump Retrofit of DOAS or New High Efficiency Unit		
Impact on System Performance	Occupant comfort will be improved slightly via new sequences and system performance.		
Impact on Operations and Maintenance	A heat pump system will require more maintenance compared to the passive heat recovery coils and electric heating coil currently in place.		
Energy and Financial Summary			
Total Project Cost:	\$625,000.00	Total Utility Bill Savings in Dollars:	\$30,207.62
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$17,390.27	+ Additional Annual Savings (Maint):	-\$3,000.00
= Total Investment:	\$607,609.73	= Total Annual Savings Estimate:	\$27,207.62
Annual Consumption Savings (kWh's):	173,902.65	Simple Payback:	22.3
Annual Demand Savings (kW):	694.70	Useful Life (years):	20
		Return on Investment:	-0.52%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

Please note that the cost presented in the table above is a **budget only** for the purpose of exploring the feasibility of this option.

3.3 ECM-1c: Solar Air Preheat for Penthouse DOAS

3.3.1 Existing Conditions

The existing DOAS unit includes a passive heat recovery coil that is approximately 60% efficient. There is also a 162kW electric coil providing additional heat to the supply to ensure a neutral air temperature is delivered to the hallways. This creates a high electric demand when all stages are active and is responsible for a large portion of building energy consumption.

3.3.2 Proposed Measure

PMC explored the option of trying to pre-heat the outdoor air using solar air heating panels. The picture below is a good representation of the concept.



Figure 4 - Example Solar AIR Preheat System

3.3.3 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback.

ECM-1c: Solar Air Preheat for Penthouse DOAS			
Measure Description	Install solar air heating system on roof using Matrix Air Delta modules. The system will provide 20,200 CFM of pre-heated fresh air to the penthouse AHU for distribution throughout the residential floors.		
Impact on System Performance	From the perspective of the occupants there will be no noticeable change.		
Impact on Operations and Maintenance	Solar air heating system will require additional maintenance for inspections and periodic snow removal.		
Energy and Financial Summary			
Total Project Cost:	\$161,520.00	Total Utility Bill Savings in Dollars:	\$7,101.68
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$6,750.00	+ Additional Annual Savings (Maint):	-\$250.00
= Total Investment:	\$154,770.00	= Total Annual Savings Estimate:	\$6,851.68
Annual Consumption Savings (kWh's):	67,500.00	Simple Payback:	22.6
Annual Demand Savings (kW):	0.00	Useful Life (years):	25
		Return on Investment:	0.43%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

3.4 ECM-2: Parkade Level Heat Pump Retrofit with VRV

3.4.1 Existing Conditions

There is considerable ventilation load associated with AH-1 in the basement providing temperature ventilation air to the elevator lobby, the hallways, the pool change rooms and the maintenance shop. PMC therefore explored opportunities to implement heat recovery between AH-1 and EF-5. We then examined how this new heat recovery system could be expanded to provide dehumidification to the storage areas via replacement of AH-2, replacement of the cabinet unit heater in the pool room stairwell as well as the addition of new dedicated cassette style unit in the gymnasium area.

3.4.2 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback.

ECM-2: Parkade Level Heat Pump Retrofit with VRV			
Measure Description	This ECM explored the opportunity to replace the aging make-up air and air handling equipment serving the P1 Parkade Level with heat pump, heat recovery technology. This ECM targets replacing AH-1 and EF-5 with a new ERV and also a post-heat VRV ducted air handling unit. ECM include replacement of AH-2 top proved dehumidification, a new cassettes style split for the gym, and a new wall-mount heat pump for the pool stairwell.		
Impact on Occupant Comfort	Occupant comfort will be improved via new sequences and system performance. The addition of cooling capacity should reduce or eliminate the need for portable dehumidification units and will also provide improved comfort to the gymnasium.		
Impact on Operations and Maintenance	A heat pump system will require more maintenance compared to the electric heating coils and heaters currently in place.		
Energy and Financial Summary			
Total Installation Estimate:	\$220,840.00	Total Utility Bill Savings in Dollars:	\$14,825.80
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$12,349.86	+ Additional Annual Savings (Maint):	\$0.00
= Total Investment:	\$208,490.14	= Total Annual Savings Estimate:	\$14,825.80
Annual Consumption Savings (kWh's):	123,498.62	Simple Payback:	14.1
Annual Demand Savings (kW):	106.88	Useful Life (years):	20
Annual Consumption Savings (GJ's):	0.00	Return on Investment:	2.11%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

NOTE: A follow-up site visit will be required to verify some installation details of the above ECM. This includes items such as condensing unit locations, electrical connections, etc.

3.5 ECM-3 – DCW Booster Pump Replacement with High Efficiency Variable Speed System

3.5.1 Existing Conditions

The existing domestic booster pump system appears to be original to the building and is comprised of two 10-hp pumps (lead/lag). It is a constant speed pumping system that does not provide any automatic variable capacity control and instead relies on pressure reduction valves at the outlet of the pump.

3.5.2 Proposed Measure

Supply and install a new high efficiency variable speed booster system to provide constant pressure at variable flow rates in an efficient manner.

3.5.3 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback.

ECM-3: DCW Booster Pump Replacement with High Efficiency Variable Speed System

Measure Description	Replace the existing fixed speed domestic booster pump system with a new variable flow high efficiency booster pump system.		
Impact on Occupant Comfort	There may be some adjustment period as the system water pressures are recommissioned.		
Impact on Operations and Maintenance	This is a new domestic pumping system which should operate reliably for many years compared to the aging system which appeared to experience failures based on audit observations.		
Energy and Financial Summary			
Total Installation Estimate:	\$68,880.00	Total Utility Bill Savings in Dollars:	\$5,579.16
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$5,500.00	+ Additional Annual Savings (Maint):	\$0.00
= Total Investment:	\$63,380.00	= Total Annual Savings Estimate:	\$5,579.16
Annual Consumption Savings (kWh's):	52,585.87	Simple Payback:	11.4
Annual Demand Savings (kW):	2.72	Useful Life (years):	20
Annual Consumption Savings (GJ's):	-	Return on Investment:	3.80%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

3.6 ECM-4: Replace DHW Tank with Heat Pumps (Qty.2)

3.6.1 Existing Conditions

The audit identified three (3) domestic hot water (DHW) tanks in the common areas on the ground floor and on the P1 level serving independent loads. There is a 61-gallon tank in the P-1 janitors' closet/storage room, a 45-gallon tank in the car wash area, and a tank of unknown size in the laundry room located behind the security office.

3.6.2 Proposed Measure

PMC proposes the replacement of two of the three existing DHW tanks serving the P-1 janitors' closet/storage room and the car wash area with heat pump water heaters (HPWH). Switching to HPWH's will yield energy savings through more efficient DHW generation. Based on manufacturer recommendations and PMC's experience with heat pump water heaters, this ECM is not suggested in the laundry room due to conflicting space limitations and ventilation requirements. It may be beneficial for Summer Gardens to implement HPWH's after the useful life of the current DHW tanks, rather than pursuing an immediate replacement.

3.6.3 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback. It is difficult to determine the current domestic hot water usage of the car wash area and janitors’ closet, due to unconventional applications. The following summary demonstrates the expected energy savings by transitioning an electric DHW tank serving **standard household loads** to a heat pump water heater. Energy savings will vary based on actual DHW consumption.

ECM-4 - Replace DHW Heaters with Heat Pumps - Qty.2			
Measure Description	Replace a standard electric DHW tank at Summer Gardens with a heat pump water heater. Replacement opportunities include the DHW tanks serving the car wash area and P-1 janitors closet/ storage area.		
Impact on Occupant Comfort	No change to occupant comfort.		
Impact on Operations and Maintenance	The heat pump water heater will require a different maintenance procedure than the existing electric DHW tank.		
Energy and Financial Summary			
Total Installation Estimate:	\$11,360.00	Total Utility Bill Savings in Dollars:	\$542.88
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$600.00	+ Additional Annual Savings (Maint):	\$0.00
= Total Investment:	\$10,760.00	= Total Annual Savings Estimate:	\$542.88
Annual Consumption Savings (kWh's):	5,160.00	Simple Payback:	19.8
Annual Demand Savings (kW):	0.00	Useful Life (years):	15
		Return on Investment:	-1.62%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

NOTE: Efficiency Nova Scotia offers a Commercial Water Heating Rebate which can allow for up to \$800 of each HPWH purchase to be recovered. Efficiency Nova Scotia must be consulted for confirmation of this incentive. For the purposes of this measure summary, a rebate of \$600 was applied assuming a 50-gallon HPWH is installed.

3.7 ECM-5 – Rooftop Solar PV Option

3.7.1 Existing Conditions

Summer Gardens has a roof area of approximately 6,650 ft² (after deducting the penthouse area) and combined with the fact that it is a tall building that is not shaded from neighbouring buildings it makes it an opportune location for rooftop solar photovoltaics. This measure analyses the feasibility of rooftop solar and provides high level budgets, and for all intents and purposes it is assumed that 2,800 ft² of this roof area can be used for solar.

3.7.2 Proposed Measure

Install a solar PV system on the roof of 1470 Summer St. Scope includes:

- Supply and install a 47-kW capacity solar PV system.
- Low profile ballasted racking system certified for flat roof.
- Micro inverter and accessories wired to electrical panel and integrated with NS Power net-metering.
- Combiner box and disconnect.
- Crane for lifting materials to roof area.
- Startup and commissioning.

3.7.3 Measure Summary

The table below provides a summary of the energy efficiency and conservation measure highlighting the impact in tenant comfort, maintenance requirements, energy savings and financial indicators such as payback.

ECM-5: Rooftop Solar PV Option			
Measure Description	Install solar PV system on roof. Estimated system capacity is 47kW. System will be net-metered with NS Power so that at any time where excess energy is being produced and not used in the building it will be sent exchanged to the grid in the form of credits.		
Impact on Occupant Comfort	No change to occupant comfort.		
Impact on Operations and Maintenance	Solar PV will require additional maintenance for inspections and periodic snow removal.		
Energy and Financial Summary			
Total Installation Estimate:	\$140,000.00	Total Utility Bill Savings in Dollars:	\$8,491.46
+ Eng. & Proj. Mgmt.:	\$0.00	- Additional Annual Costs:	\$0.00
- Efficiency NS Incentive (Pending Approvals):	\$0.00	+ Additional Annual Savings (Maint):	\$0.00
= Total Investment:	\$140,000.00	= Total Annual Savings Estimate:	\$8,491.46
Annual Consumption Savings (kWh's):	50,866.67	Simple Payback:	16.5
Annual Demand Savings (kW):	183.12	Useful Life (years):	30
		Return on Investment:	2.73%
Elect. Consumption Rate - 1st Tier (per kWh):	\$0.13817	Elect. Consumption Rate - 2nd Tier (per kWh):	\$0.10521
Electrical Demand Rate (max monthly kW):	\$10.554		

NOTE:

- Simple payback and ROI are based on fixed rates and does not account for NS Power annual rate increases.
- Accelerated CCA rate incentives are also available, however, not included in the above analysis.

3.8 Additional Opportunities & Recommendations

In addition to the formal ECMs identified and summarized above, PMC also completed a high-level review of other potential opportunities and capital replacement recommendations for consideration.

Winter Vestibule

The main entrance to Summer Gardens uses motion-activated double sliding doors and a single manual door for access into the building. These doors open to a small vestibule placed alongside the security office, served by three unit heaters. While on site, it was observed that many residents will stop in the vestibule to chat with the Commissionaire, which frequently causes the automatic sliding doors to open unnecessarily. In the winter, gusts of cold air enter the building each time the main doors are opened increasing the heating load required to maintain comfortable conditions in the vestibule.

PMC examined the concept of a seasonal vestibule outside of the main entrance to Summer Gardens during the winter months, to prevent these gusts of cold air from entering the building. The temporary structure will serve as a barrier against the strong head winds faced by the main entrance. The vestibule will be designed with both cosmetics and accessibility in mind (see examples below), and can be installed/removed by Summer Gardens staff.



Figure 5 - Example Winter Vestibule

As an additional measure, the motion sensors operating the sliding double doors can be replaced with interior and exterior push buttons. This will prevent the doors from opening unnecessarily from accidental motion sensor trips, therefore reducing the amount of cold air entering the space.

Replace Dectron Unit

At the time of the inspection the Dectron unit appeared to be functional, and reports indicated that it may have been recently repaired.

The unit is quite old and has exceeded its ASHRAE recommended lifespan. Dectron offers many variations within their product line and there are other options that are more efficient than the current unit. We reached out to the Dectron representative and they are providing several efficiency options for review (still pending at time of this report).

In the short term, PMC recommends implementation of ECM-1 which will provide connection and control over the existing Dectron unit, its duct heater, and the pool heater. ECM-1 also includes replacement dampers and new control sequences to maximize the opportunities for cooling or low-cost dehumidification using outdoor air when conditions were favourable. With the new BAS in place additional trend data will allow for more accurate assessment of the current units, functionality and efficiency so that its replacement can be more carefully considered.

Life Safety Systems

If not already completed PMC recommends a thorough inspection of the life safety systems observed during our audit. This includes the fire alarming and smoke exhaust system associated with the Penthouse DOAS system as well as the CO/NO system serving the parkade. The dampers associated with the CO/NO system should also be scheduled for replacement. **UPDATE:** The board confirmed that these systems have recently been inspected and minor repairs were underway.

3.9 ECM Summary Table

ECM #	Description of Item	Total Annual kWh Savings	Total Annual kW Savings	Total Annual (\$) Utility Savings	Additional Costs or Savings (\$)	Construction & Engineering Cost (\$)	Total Estimated Incentive (\$)	Net Project Investment (\$)	Life Expectancy (years)	Simple Payback (years)	Return on Investment
1	New Building Automation System (BAS), Repairs, Recommissioning	123,498.62	106.88	\$14,825.80	\$0.00	\$159,660.00	\$12,349.86	\$147,310.14	20	9.94	5.06%
1b	Heat Pump Retrofit for Penthouse DOAS	173,902.65	694.70	\$30,207.62	-\$3,000.00	\$625,000.00	\$17,390.27	\$607,609.73	20	22.33	-0.52%
1c	Solar Air Preheat for Penthouse DOAS	67,500.00	0.00	\$7,101.68	-\$250.00	\$161,520.00	\$6,750.00	\$154,770.00	25	22.59	0.43%
2	Parkade Level Heat Pump Retrofit with VRV	123,498.62	106.88	\$14,825.80	\$0.00	\$220,840.00	\$12,349.86	\$208,490.14	20	14.06	2.11%
3	DCW Booster Pump Replacement with High Efficiency Variable Speed System	52,585.87	2.72	\$5,579.16	\$0.00	\$68,880.00	\$5,500.00	\$63,380.00	20	11.36	3.80%
4	Replace DHW Heaters with Heat Pumps - Qty.2	5,160.00	0.00	\$542.88	\$0.00	\$11,360.00	\$600.00	\$10,760.00	15	19.82	-1.62%
5	Rooftop Solar PV Option	50,866.67	183.12	\$8,491.46	\$0.00	\$140,000.00	\$0.00	\$140,000.00	30	16.49	2.73%
6 - HM	Winter Vestibule Enclosure (see pictures)	<i>Hard to Calculate</i>	N/A	<i>Hard to Calculate</i>	\$0.00	\$10,000.00	N/A	\$10,000.00	<i>Unknown</i>	<i>Unknown</i>	<i>Unknown</i>
CAP REC	Pool - Replace Dectron Unit	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	<i>TBD</i>	20	<i>TBD</i>	<i>TBD</i>
CAP REC	Replace CO/NO System, Replace OA Dampers, Inspect Fans	N/A	N/A	N/A	N/A	<i>TBD</i>	N/A	<i>TBD</i>	20	N/A	N/A

Please Note: Figures shown in red in the table above are budget costs only. These items require further investigation and revisions should the ECM be pursued.

APPENDIX A – Utility Baseline

SUMMARY OF TWO METERS

	6-Jan-2020	6-Feb-2020	6-Mar-2020	9-Apr-2020	11-May-2020	5-Jun-2020	8-Jul-2020	6-Aug-2020	4-Sep-2020	7-Oct-2020	9-Nov-2020	7-Dec-2020	
Period	6-Feb-2020	6-Mar-2020	9-Apr-2020	11-May-2020	5-Jun-2020	8-Jul-2020	6-Aug-2020	4-Sep-2020	7-Oct-2020	9-Nov-2020	7-Dec-2020	7-Jan-2021	
2020	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	TOTAL
Days in billing period	31	29	34	32	25	33	29	29	33	33	28	31	367
Consumption (kWh)	132,820	119,880	128,640	98,240	44,640	47,660	31,440	30,040	41,160	76,800	79,920	106,640	937,880
Demand (kW)	275.4	266.4	245.0	210.2	235.1	123.8	100.8	83.9	108.9	210.4	227.4	236.6	2,324
Energy Cost (\$-HST)	\$6,761.62	\$6,540.65	\$6,015.24	\$5,160.83	\$5,480.00	\$3,039.54	\$2,474.84	\$2,059.92	\$2,673.71	\$5,165.74	\$5,583.12	\$11,210.80	\$62,166.01
Energy Cost (\$-HST)	\$6,994.27	\$5,992.00	\$7,165.21	\$5,056.31	\$0.00	\$2,060.31	\$1,014.86	\$1,193.00	\$1,743.62	\$3,123.76	\$3,098.56	\$1,409.35	\$38,851.25
Demand Cost (\$-HST)	\$2,890.88	\$2,796.40	\$2,571.77	\$2,206.47	\$2,467.84	\$1,299.53	\$1,058.10	\$880.70	\$1,143.12	\$2,208.57	\$2,387.01	\$2,483.59	\$24,393.98
Total Cost (\$-HST)	\$16,646.77	\$15,329.05	\$15,752.22	\$12,423.61	\$7,947.84	\$6,399.38	\$4,547.80	\$4,133.62	\$5,560.45	\$10,498.07	\$11,068.69	\$15,103.74	\$125,411.24
Average Cost per kWh	\$0.10	\$0.10	\$0.10	\$0.10	\$0.12	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.11	\$0.12	\$0.11
Average Cost per kW	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50	\$10.50

Common Area (sq.ft): **23,633**

Energy Index (kWh / sq.ft / year): **39.685**

APPENDIX B – Energy Calculations

Calculation of Energy Consumption by Equipment End-Use

Lights									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Lights									
Lighting as per Previous Audit	56,636.42	85.76	7.15	56,636.42	85.76	7.15	0.00	0.00	
Watts per Square Foot (interior only)			0.302			0.03			
	56,636.42	85.76	7.15	56,636.42	85.76	7.17	0.00	0.00	Annual Savings
							0.000		\$0.000
							Equiv. G's		

Fans - Motor Savings									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Fans - Motor Savings									
SF-1 - New EC Fan Grid for Penthouse DOAS	106,872.00	146.40	12.20	80,190.34	129.71	10.81	26,681.66	16.69	ECM-1 - New BAS, Improved Scheduling & Sequence
EF-1 - Exhaust Fan for Penthouse DOAS	49,362.16	67.62	5.63	32,673.43	57.81	4.82	16,688.73	9.80	ECM-1 - New BAS, Add VFD, Improved Scheduling & Sequence
Exhaust Fans - Qty.14	19,805.35	35.39	5.90	16,778.23	36.47	6.08	3,027.12	-1.09	ECM-1 - New BAS, Improved Scheduling & Sequence
Unit Heater Fans	2,422.85	7.14	1.02	2,198.16	6.63	0.95	224.69	0.51	ECM-2 - New VRV System (for Unit Heaters at Rear Entrance)
AH-1	7,921.16	10.85	0.90	6,657.60	9.12	0.76	1,263.56	1.73	ECM-2 - New VRV System to Replace AH-1
AH-2	0.00	0.00	0.00	6,657.60	9.12	0.76	-6,657.60	-9.12	ECM-2 - New VRV System to Replace AH-2 (hasn't been workin in a while!)
	186,383.52	267.40	25.66	145,155.35	248.87	24.17	41,228.17	18.53	Annual Savings
							148.421		\$4,655.252
							Equiv. G's		

Pumps - Motor Savings									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Pumps - Motor Savings									
Pool Pump 1-hp	8,378.15	11.48	0.96	8,378.15	11.48	0.96	0.00	0.00	ECM-1 Connect to BAS for Demand Limiting
Domestic Booster Pumps	63,723.38	100.02	8.34	11,137.51	97.30	8.11	52,585.87	2.72	ECM-3 - New Booster Pumps
	72,101.53	111.50	9.29	19,515.66	108.78	9.07	52,585.87	2.72	Annual Savings
							189.309		\$5,579.162
							Equiv. G's		

Ventilation									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Ventilation									
Penthouse DOAS - BAS Upgrades and Damper Retrofit	317,071.44	1,054.70	162.00	257,849.72	949.23	162.00	59,221.72	105.47	ECM-1 - New BAS, Dampers, Etc..
ECM-1 plus ECM-1b (upgrade to A.I.R Heat Pump)	-	-	-	143,168.79	360.00	40.00	173,902.65	694.70	ECM-1b - Upgrade to A.I.R Heat Pump
ECM-1 plus ECM-1c (Matrix Air Preheat)	-	-	-	0.00	0.00	0.00	67,500.00	0.00	ECM-1c - Matrix AIR Preheat
AH-1 - Ground Floor Lobby, Maint, Locker Rooms, Gym	132,613.16	259.23	49.38	18,912.02	95.10	9.26	113,701.14	164.12	ECM-2 - New ERV and VRV Head to Replace AH-1 and EF-5
AH-2 - Storage Area	0.00	0.00	0.00	6,835.43	24.13	0.77	-6,835.43	-24.13	ECM-2 - Replace Inactive AH-2 with new VRV Head and Mixing Box
	449,684.60	1,313.93	211.38	426,765.95	1,428.47	212.03	407,490.09	940.16	Annual Savings
							1,466.964		\$58,992.017
							Equiv. G's		

Heating									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Heating									
Space Heating for HUH's, CUH's and Misc BB's	87,722.88	360.00	60.00	83,279.49	360.00	60.00	4,443.39	0.00	ECM-1 - Add Heaters to new BAS and Setback
Space Heating for CUH-6	20,470.10	112.00	14.00	8,539.21	112.00	14.00	11,940.89	0.00	ECM-2 - New VRV System to Replace CUH-6
Pool Water Heating	27,867.00	156.00	30.00	18,450.00	180.00	30.00	9,417.00	-24.00	ECM-1 - Add to BAS for Demand Management
Jacuzzi Heater	2,730.00	84.00	14.00	2,730.00	84.00	14.00	0.00	0.00	
Mini-Split in Lounge / Lobby Areas - Qty.2 (H&C)	7,416.96	36.36	3.03	7,416.96	36.36	3.03	0.00	0.00	
Sauna Heaters (Qty.3 in Total)	10,000.00	60.00	10.00	10,000.00	60.00	10.00	0.00	0.00	
Space Heating for Pool Area							0.00	0.00	
	156,206.93	808.36	131.03	130,405.65	832.36	131.03	25,801.28	-24.00	Annual Savings
							92.885		\$2,303.049
							Equiv. G's		

Cooling									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Cooling									

Calculation of Energy Consumption by Equipment End-Use

Dectron - Pool Deck Cooling and Dehumidification	17,273.00	119.76	9.98	13,254.00	119.76	9.98	4,019.00	0.00	ECM-1 - Add Dectron to BAS, Update SP's, Purge Functionality
VRV Cooling for VRV IDU replacing CUH-6, Gym	0.00	0.00	0.00	3,466.72	8.67	2.17	-3,466.72	-8.67	ECM-2 - New VRV System to Rpelace CUH-6 and Add Cooling to Gym
	17,273.00	119.76	9.98	16,720.72	128.43	12.15	552.28	-8.67	Annual Savings
							1.988		\$-90.496
							Equiv. GJ's		

Hot Water									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Electric DHW Heater x Qty.3 - See Claire's Estimate	10,482.00	54.00	4.50	5,322.00	54.00	4.50	5,160.00	-	ECM-4 - Heat Pump DHW Tank for Two of the Three Common Area Tanks
	10,482.00	54.00	4.50	5,322.00	54.00	4.50	5,160.00	0.00	Annual Savings
							18.576		\$542.884
							Equiv. GJ's		

Miscellaneous									
Equipment Description	Pre-Project Energy			Post-Project Energy			Annual Savings		Description of ECM
	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	Monthly Demand kW	Consumption (kWh/yr)	Demand (kW/yr)	
Elevator	46,169.07	314.54	26.21	46,169.07	314.54	26.21	0.00	0.00	
Portable Dehum Units - Qty.3	3,077.95	7.65	1.53	0.00	0.00	0.00	3,077.95	7.65	ECM-2 - Will provide dehum so these are not necessary
	49,247.01	322.19	27.74	46,169.07	314.54	26.21	3,077.95	7.65	Annual Savings

Calculated TOTAL(s):	998,015.02	2,466.32		846,690.84	2,560.97		535,895.62	936.39	\$72,436.930
Actual Utility Baseline:	937,880.00	2,323.90					151,324.18	-94.65	kWh and kW Savings
Percent of Actual:	106.41%	106.13%							
Difference:	60,135.02	142.42							

	Consumption (kWh)	(Demand kW)
Calculated Totals:	998,015.02	2,466.32
Proposed Baseline (2020):	937,880.00	2,323.90
Percent of Actual:	106.41%	106.13%

DOAS Fan Energy

Current Energy Use

Proposed Energy Use

SF-1 - Penthouse DOAS				<i>Nominal HP</i>	*Peak of 15kW (23-amp)
Eff.	kw	Run Hours	kWh	-	
-	12.200	8760	106,872		
<small>kw = (hp*0.746) / (%EF)</small>					

Load Profile & Projected Annual Energy Use				Weighted Demand		
Flow	% of Time	Run Hours	kWh			
100%	100%	8,760	106,872	12.20		
90%	0%	0	0	10.98		
80%	0%	0	0	9.76		
70%	0%	0	0	8.54		
60%	0%	0	0	7.32		
50%	0%	0	0	6.10		
40%	0%	0	0	4.88		
30%	0%	0	0	3.66		
20%	0%	0	0	2.44		
10%	0%	0	0	1.22		
0%	0%	0	0	0.00		
			100%	8,760	106,872	W.AVG: 12.20

EF-1 - Penthouse DOAS				<i>7.5 Nominal HP</i>	<i>bhp</i>
Eff.	kw	Run Hours	kWh	6.7	
88.7%	5.635	8760	49,362		
<small>kw = (hp*0.746) / (%EF)</small>					

Load Profile & Projected Annual Energy Use				Weighted Demand		
Flow	% of Time	Run Hours	kWh			
100%	100%	8,760	49,362	5.63		
85%	0%	0	0	4.79		
80%	0%	0	0	4.51		
70%	0%	0	0	3.94		
60%	0%	0	0	3.38		
50%	0%	0	0	2.82		
40%	0%	0	0	2.25		
30%	0%	0	0	1.69		
20%	0%	0	0	1.13		
10%	0%	0	0	0.56		
0%	0%	0	0	0.00		
			100%	8,760	49,362	W.AVG: 5.63

TOTALS:		kWh	kw
		156,234	17.8

SF-1 - Penthouse DOAS				<i>Nominal HP</i>	-
Eff.	kw	Run Hours	kWh	-	
-	12.200	8760	106,872		
<small>kw = (hp*0.746) / (%EF)</small>					

Load Profile & Projected Annual Energy Use				Weighted Demand		
Flow	% of Time	Run Hours	kWh			
100%	62%	5,431	66,261	12.20		
90%	0%	0	0	10.98		
80%	0%	0	0	9.76		
70%	38%	3,329	13,930	8.54		
60%	0%	0	0	7.32		
50%	0%	0	0	6.10		
40%	0%	0	0	4.88		
30%	0%	0	0	3.66		
20%	0%	0	0	2.44		
10%	0%	0	0	1.22		
0%	0%	0	0	0.00		
			100%	8,760	80,190	W.AVG: 10.81

EF-1 - Penthouse DOAS				<i>7.5 Nominal HP</i>	<i>bhp</i>
Eff.	kw	Run Hours	kWh	6.7	
89%	5.635	8760	49,362		
<small>kw = (hp*0.746) / (%EF)</small>					

Load Profile & Projected Annual Energy Use				Weighted Demand		
Flow	% of Time	Run Hours	kWh			
95%	62%	5,431	26,240	5.35		
90%	0%	0	0	5.07		
80%	0%	0	0	4.51		
70%	38%	3,329	6,434	3.94		
60%	0%	0	0	3.38		
50%	0%	0	0	2.82		
40%	0%	0	0	2.25		
30%	0%	0	0	1.69		
20%	0%	0	0	1.13		
10%	0%	0	0	0.56		
0%	0%	0	0	0.00		
			100%	8,760	32,673	W.AVG: 4.82

TOTALS:		kWh	kw
		112,864	15.6

AH-1,AH-2 Fan Energy

Current Energy Use

Proposed Energy Use

AH-1			<i>Nominal HP</i>
			1.0

Eff.	kW	Run Hours	kWh
83%	0.904	8760	7,921

$kw = (hp \cdot 0.746) / (\%EF)$

AH-2			<i>Nominal HP</i>
			1.0

Eff.	kw	Run Hours	kWh
83.0%	0.899	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

AH-1 - Replace with VRV Unit			<i>Nominal HP</i>
			-

Eff.	kW	Run Hours	kWh
-	0.760	8760	6,658

$kw = (hp \cdot 0.746) / (\%EF)$

AH-2 - Replace with VRV Unit			<i>Nominal HP</i>
			-

Eff.	kw	Run Hours	kWh
-	0.760	8760	6,658

$kw = (hp \cdot 0.746) / (\%EF)$

Exhaust Fan Energy

Current Energy Use		
	kWh	kW
EF-2 - Dryer Exhaust	6,283.62	0.72
EF-3 - Dryer Exhaust	6,283.62	0.72
RE-1 - Roof Exhauster	0.00	0.24
RE-2 - Roof Exhauster	0.00	0.24
RE-3 - Roof Exhauster	1,075.96	0.72
EF-4 - Garbage Rm Exhaust	2,094.54	0.24
EF-5 - Exhaust for AH-1	2,792.44	0.32
EF-6 - Parkade Exhaust CO/NO	159.39	0.32
EF-7 - Parkade Exhaust CO/NO	159.39	0.32
EF-8 - Parkade Exhaust CO/NO	239.10	0.48
EF-9 - Parkade Exhaust CO/NO	239.10	0.48
EF-10 - Parkade Exhaust CO/NO	239.10	0.48
EF-11 - P1 Electrical Vault Exhaust	239.10	0.32
EF-12 - Ground Floor Lounge Exhaust	0.00	0.32
TOTAL(s)	19,805.35	5.90

Proposed Energy Use		
	kWh	kW
EF-2 - Dryer Exhaust	3,916.50	0.72
EF-3 - Dryer Exhaust	3,916.50	0.72
RE-1 - Roof Exhauster	0.00	0.24
RE-2 - Roof Exhauster	119.55	0.24
RE-3 - Roof Exhauster	1,075.96	0.72
EF-4 - Garbage Rm Exhaust	2,094.54	0.24
EF-5 - Exhaust for AH-1	4,380.00	0.50
EF-6 - Parkade Exhaust CO/NO	159.39	0.32
EF-7 - Parkade Exhaust CO/NO	159.39	0.32
EF-8 - Parkade Exhaust CO/NO	239.10	0.48
EF-9 - Parkade Exhaust CO/NO	239.10	0.48
EF-10 - Parkade Exhaust CO/NO	239.10	0.48
EF-11 - P1 Electrical Vault Exhaust	239.10	0.32
EF-12 - Ground Floor Lounge Exhaust	0.00	0.32
TOTAL(s)	16,778.23	6.08

EF-2 - Dryer Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.72	8760	6,284	0.750
kw = (hp*0.746) / (%EF)				

EF-2 - Dryer Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.72	5460	3,917	0.750
kw = (hp*0.746) / (%EF)				

EF-3 - Dryer Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.72	8760	6,284	0.750
kw = (hp*0.746) / (%EF)				

EF-3 - Dryer Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.72	5460	3,917	0.750
kw = (hp*0.746) / (%EF)				

RE-1 - Roof Exhauster (Smoke Extraction)				HP
Eff.	kw	Run Hours	kWh	
78%	0.24	0	0	0.250
kw = (hp*0.746) / (%EF)				

RE-1 - Roof Exhauster (Smoke Extraction)				HP
Eff.	kw	Run Hours	kWh	
78%	0.24	0	0	0.250
kw = (hp*0.746) / (%EF)				

RE-2 - Roof Exhauster Penthouse Exhaust (BROKEN?)				HP
Eff.	kw	Run Hours	kWh	
78%	0.24	0	0	0.250
kw = (hp*0.746) / (%EF)				

RE-2 - Roof Exhauster Penthouse Exhaust (BROKEN?)				HP
Eff.	kw	Run Hours	kWh	
78%	0.24	500	120	0.250
kw = (hp*0.746) / (%EF)				

RE-3 - Roof Exhauster Elevator Machine Room				HP
Eff.	kw	Run Hours	kWh	
78%	0.72	1500	1,076	0.750
kw = (hp*0.746) / (%EF)				

RE-3 - Roof Exhauster Elevator Machine Room				HP
Eff.	kw	Run Hours	kWh	
78%	0.72	1500	1,076	0.750
kw = (hp*0.746) / (%EF)				

EF-4 - Garbage Rm Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.24	8760	2,095	0.250
kw = (hp*0.746) / (%EF)				

EF-4 - Garbage Rm Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.24	8760	2,095	0.250
kw = (hp*0.746) / (%EF)				

EF-5 - Exhaust for AH-1				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	8760	2,792	0.333
kw = (hp*0.746) / (%EF)				

EF-5 - Exhaust Replace with ERV				HP
Eff.	kw	Run Hours	kWh	
-	0.50	8760	4,380	-
kw = (hp*0.746) / (%EF)				

EF-6 - Parkade Exhaust CO/NO (BROKEN?)				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	500	159	0.333
kw = (hp*0.746) / (%EF)				

EF-6 - Parkade Exhaust CO/NO (BROKEN?)				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	500	159	0.333
kw = (hp*0.746) / (%EF)				

EF-7 - Parkade Exhaust CO/NO (BROKEN?)				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	500	159	0.333
kw = (hp*0.746) / (%EF)				

EF-7 - Parkade Exhaust CO/NO (BROKEN?)				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	500	159	0.333
kw = (hp*0.746) / (%EF)				

EF-8 - Parkade Exhaust CO/NO				HP
Eff.	kw	Run Hours	kWh	
78%	0.48	500	239	0.500
kw = (hp*0.746) / (%EF)				

EF-8 - Parkade Exhaust CO/NO				HP
Eff.	kw	Run Hours	kWh	
78%	0.48	500	239	0.500
kw = (hp*0.746) / (%EF)				

EF-9 - Parkade Exhaust CO/NO				HP
Eff.	kw	Run Hours	kWh	
78%	0.48	500	239	0.500
kw = (hp*0.746) / (%EF)				

EF-9 - Parkade Exhaust CO/NO				HP
Eff.	kw	Run Hours	kWh	
78%	0.48	500	239	0.500
kw = (hp*0.746) / (%EF)				

EF-10 - Parkade Exhaust CO/NO				HP
Eff.	kw	Run Hours	kWh	
78%	0.48	500	239	0.500
kw = (hp*0.746) / (%EF)				

EF-10 - Parkade Exhaust CO/NO				HP
Eff.	kw	Run Hours	kWh	
78%	0.48	500	239	0.500
kw = (hp*0.746) / (%EF)				

EF-11 - P1 Electrical Vault Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	750	239	0.333
kw = (hp*0.746) / (%EF)				

EF-11 - P1 Electrical Vault Exhaust				HP
Eff.	kw	Run Hours	kWh	
78%	0.32	750	239	0.333
kw = (hp*0.746) / (%EF)				

Exhaust Fan Energy

EF-2 - Dryer Exhaust		0.750
		HP
EF-12 - Ground Floor Lounge Exhaust (BROKEN?)		0.333
Eff.	kw	Run Hours
78%	0.32	0
<small>kw = (hp*0.746) / (%EF)</small>		



EF-2 - Dryer Exhaust		0.750
		HP
EF-12 - Ground Floor Lounge Exhaust (BROKEN?)		0.333
Eff.	kw	Run Hours
78%	0.32	0
<small>kw = (hp*0.746) / (%EF)</small>		

Unit Heater Fan Energy

Current Energy Use		
	kWh	kW
HUH-1 - Penthouse	0.00	0.00
HUH-2 - Elevator Machine Room	0.00	0.00
CUH-1 - Front Entrance	573.85	0.19
CUH-2 - Front Entrance	318.80	0.13
CUH-3 Mail Room	0.00	0.00
CUH-4 Delivery Room	0.00	0.00
CUH-5 Rear Entrance	573.85	0.19
CUH-6 Pool Stairwell	382.56	0.19
CUH-7 Pool Area Washrooms	573.79	0.32
TOTAL(s)	2,422.85	1.02

Proposed Energy Use		
	kWh	kW
HUH-1 - Penthouse	0.00	0.00
HUH-2 - Elevator Machine Room	0.00	0.00
CUH-1 - Front Entrance	526.03	0.19
CUH-2 - Front Entrance	286.92	0.13
CUH-3 Mail Room	0.00	0.00
CUH-4 Delivery Room	0.00	0.00
CUH-5 Rear Entrance	573.85	0.19
CUH-6 Pool Stairwell	237.57	0.12
CUH-7 Pool Area Washrooms	573.79	0.32
TOTAL(s)	2,198.16	0.95

ECM Summary

- Add to BAS
- Add to BAS
- Add to BAS
- Add to BAS
- Replace with VRV
- Add to BAS

Fan Energy Captured in Heating

HUH-1 - Penthouse			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

HUH-2 - Elevator Machine Room			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-1 - Front Entrance			
Eff.	kw	Run Hours	kWh
78%	0.19	3000	574

$kw = (hp \cdot 0.746) / (\%EF)$

Qty.2 @ 1/15-hp Each

CUH-2 - Front Entrance			
Eff.	kw	Run Hours	kWh
78%	0.13	2500	319

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

CUH-3 Mail Room			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

CUH-4 Delivery Room			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-5 Rear Entrance			
Eff.	kw	Run Hours	kWh
78%	0.19	3000	574

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-6 Pool Stairwell			
Eff.	kw	Run Hours	kWh
78%	0.19	2000	383

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-7 Pool Area Washrooms			
Eff.	kw	Run Hours	kWh
78%	0.32	1800	574

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

HUH-1 - Penthouse			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

HUH-2 - Elevator Machine Room			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-1 - Front Entrance			
Eff.	kw	Run Hours	kWh
78%	0.19	2750	526

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-2 - Front Entrance			
Eff.	kw	Run Hours	kWh
78%	0.13	2250	287

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

CUH-3 Mail Room			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

Fan Energy Captured in Heating

CUH-4 Delivery Room			
Eff.	kw	Run Hours	kWh
78%	0.00	0	0

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-5 Rear Entrance			
Eff.	kw	Run Hours	kWh
78%	0.19	3000	574

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-6 Pool Stairwell			
Eff.	kw	Run Hours	kWh
78%	0.12	2000	238

$kw = (hp \cdot 0.746) / (\%EF)$

HP

CUH-7 Pool Area Washrooms			
Eff.	kw	Run Hours	kWh
78%	0.32	1800	574

$kw = (hp \cdot 0.746) / (\%EF)$

Add to BAS

Add to BAS

VRV - New Head FXAQ24PVJU

Pump Energy

Current Energy Use

Pool Pump 1.0

Eff.	kw	Run Hours	kWh
78%	0.956	8760	8,378

$$kw = (hp \cdot 0.746) / (\%EF)$$

HP

Booster Pump 10.00

Eff.	kw	Run Hours	kWh
90%	8.335	8760	73,016

$$kw = (hp \cdot 0.746) / (\%EF)$$

Proposed Energy Use

Pool Pump 1.0

Eff.	kw	Run Hours	kWh
78%	0.956	8760	8,378

$$kw = (hp \cdot 0.746) / (\%EF)$$

HP

Booster Pump 10.0

Eff.	kw	Run Hours	kWh
92%	8.109	5000	40,543

$$kw = (hp \cdot 0.746) / (\%EF)$$

Domestic Booster Pump System

DOMESTIC WATER PRESSURE BOOSTER SYSTEM

EQUIP. NO.	SERVICE LOCATION	NO. OF PUMPS	GPM/EA PUMP	SYSTEM PRESSURE VALUES				MOTOR DATA AND VALUES			CONTROL PANEL				REMARKS	DESIGN BASIS MODEL
				TDH [Feet]	SUCTION [PSI]	BOOST [PSI]	SET [PSI]	RPM	HP	kWh PER YR.	VOLTAGE	PHASE	FULL LOAD	MAX. SCCR		
		2	45	180	35	77.92	112.92	3,450	5	11137.51	575	Three Phase	12.4	100KAIC	1, 2, 3, 4, 5, 6, 7, 8, 9, 10,11	QUANTUMFLO-35205: GENIUS DUPLEX QVD_10/5

1. NET BOOST PRESSURE IS CALCULATED BY SYSTEM SET PRESSURE MINUS SUCTION PRESSURE LESS SYSTEM LOSSES OF 5 PSI
2. SYSTEM SUBMITTALS SHALL INCLUDE CERTIFICATE NUMBER FOR NSF61 CERTIFICATION, UL508A AND QCZJ 3RD PARTY COMPLIANCE.
3. SYSTEM CONTROLS MUST COMPLY WITH AND PROVIDE FOR EITHER CONTROL LOGIC OR REMOTE SENSOR IN ACCORDANCE WITH ANSI/ASHRAE/IES STANDARD 90.1 ENERGY STANDARD
4. PROVIDE 5-YEAR WARRANTY ON COMPLETE SYSTEM AND INCLUDE WARRANTY CERTIFICATE WITH DETAILS IN SUBMITTALS
5. SYSTEM SHALL BE PRE-SET TO SYSTEM SITE CONDITIONS BY SIMULATING SUCTION PRESSURE. HYDROSTATIC-ONLY TESTING IS NOT ACCEPTABLE.
6. THE INDUSTRIAL CONTROLLER SHALL BE IN COMPLIANCE WITH CURRENT NEC, SECTION 409.110 HAVING A MAXIMUM 100K AVAILABLE FAULT CURRENT.
7. SCCR RATINGS MUST BE INCLUSIVE OF ALL COMPONENTS WITHIN THE ENCLOSURE WITHOUT THE NEED TO PROVIDE ADDITIONAL UPSTREAM PROTECTION.
8. EQUAL SYSTEMS MUST SHOW MATHEMATICAL ANALYSIS PROVING THAT THE ALTERNATE SUPPLIER MEETS OR EXCEEDS THE KW CAPACITY LISTED.
9. PROVIDE THE FOLLOWING OPTIONS: GENERAL ALARM DRY CONTACT RELAY; MONITORS: SENSOR FAIL, LOW SUCTION/LEVEL & HIGH SYSTEM AND VFD FAULTS, PERMISSIVE RUN INPUT. REQUIRES BMS DRY CONTACT RELAY. ALLOWS THE SYST
10. REPRESENTATIVE: ENVIROAIR INDUSTRIES, INC.. PHONE: (514) 738-9865
11. BASED ON PROJECT: 1470 SUMMER STREET (035205)

Ventilation Air DOAS - BAS

BASE CASE Energy Use

Based on Sample Airflow Tests:	15,940	Hrs per Day
Design Supply Airflow Rate:	20,200	24.0
Design Exhaust Airflow Rate:	21,500	

Fresh-Air Replacement - Sensible Heating Load

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
1,118,964.60	15,940	66	1	327.94

Sensible Heating Load

Q (Btu/hr)	Operating Hours
1,118,964.60	24.0

118.1

Annual Cost for Electric

Efficiency	HDD (66F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	7.274	66	1	880,754.00

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
17.07	-17	19	4.041	176,047.23

Total Annual Heating kWh's: 880,754.00

ERV Effectiveness: 64%

Total Annual Heating kWh's: 317,071.44

AIR HP Total Annual Heating kWh's: 176,047.23

Proposed Energy Use - Daytime Hours

Based on Sample Airflow Tests:	15,940	15,940	Hrs per Day
Design Supply Airflow Rate:	20,200		15.0
Design Exhaust Airflow Rate:	21,500		

Fresh-Air Replacement - Sensible Heating Capacity

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
1,118,988.00	15,940	66	1	327.94

Sensible Heating Load

Q (Btu/hr)	Operating Hours
1,118,988.00	15.0

Annual Cost for Electric

Efficiency	HDD (66F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	7.274	66	1	550,482.76

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
17.07	-17	19	4.041	110,034.26

64.44

Total Annual Heating kWh's: 550,482.76

Heat Coil Effectiveness: 64%

Total Annual Heating kWh's: 198,173.79

AIR HP Total Annual Heating kWh's: 110,034.26

	F - HDD	C - HDD
To convert °F HDD to °C HDD: °C HDD = (5/9) x (°F HDD)	7559.0	4199.4
To convert °C HDD to °F HDD: °F HDD = (9/5) x (°C HDD)	5761.6	3200.9

Proposed Energy Use - After Hours

Based on Sample Airflow Tests:	15,940	8,000	Hrs per Day
Design Supply Airflow Rate:	20,200		9.0
Design Exhaust Airflow Rate:	21,500		

Fresh-Air Replacement - Sensible Heating Capacity

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
561,600.00	8,000	66	1	164.59

Sensible Heating Load

Q (Btu/hr)	Operating Hours
561,600.00	9.0

Annual Cost for Electric

Efficiency	HDD (66F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	7.274	66	1	165,766.45

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
17.07	-17	19	4.041	33,134.53

64.44

Total Annual Heating kWh's: 165,766.45

Heat Coil Effectiveness: 64%

Total Annual Heating kWh's: 59,675.92

AIR HP Total Annual Heating kWh's: 33,134.53

	F - HDD	C - HDD
To convert °F HDD to °C HDD: °C HDD = (5/9) x (°F HDD)	7559.0	4199.4
To convert °C HDD to °F HDD: °F HDD = (9/5) x (°C HDD)	7273.6	4040.9

Ventilation Air AH-1

BASE CASE Energy Use - Heating Only

AH-1 Flow (per dwg's) :	2,400	Hrs per Day	24.0
EF-5 Flow (per dwg's):	2,100		

Fresh-Air Replacement - Sensible Heating Load

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
168,480.00	2,400	66	1	49.38

Sensible Heating Load

Q (Btu/hr)	Operating Hours
168,480.00	24.0

Annual Cost for Electric

Efficiency	HDD (66F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	7,274	66	1	132,613.16

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
8.19	-17.2	19	4,041	55,247.61

Fresh-Air Replacement - Latent Load - Dehumidification

Q (Btu/hr)	Total cfm	H1	H2	Q (kW)
0.00	2,400	0.0138	0.0085	0.00

Latent Load - Dehumidification

Q (Btu/hr)	Operating Hours
0.00	24.0

Annual Cost for Chiller

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	0.00

Fresh-Air Replacement

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
0.00	2,400	72	83	0.00

Cooling Load

Q (Btu/hr)	Operating Hours
0.00	24.0

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	0.00

Total Annual Cooling kWh: 0.00
 Total Annual Heating kWh's: 132,613.16

Proposed Energy Use - Replace Unit with VRV HP & ERV

AH-1 Flow (per dwg's) :	2,400	2,400	Hrs per Day	24.0
EF-5 Flow (per dwg's):	2,100			

Fresh-Air Replacement - Sensible Heating Capacity

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
168,480.00	2,400	66	1	49.38

Sensible Heating Load

Q (Btu/hr)	Operating Hours
168,480.00	24.0

Annual Cost for Electric

Efficiency	HDD (7F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	22	7	-1	395.64

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
8.19	-17.2	19	4,041	55,248.83

9.257142857 kW of HP

Fresh-Air Replacement - Latent Load - Dehumidification

Q (Btu/hr)	Total cfm	H1	H2	Q (kW)
61,564.80	2,400	0.0138	0.0085	18.04

Latent Load - Dehumidification

Q (Btu/hr)	Operating Hours
61,564.80	24.0

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	1,776.77

5.261948718 kW of Heat Pump

Fresh-Air Replacement

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
29,040.00	2,400	72	83	8.51

Cooling Load

Q (Btu/hr)	Operating Hours
29,040.00	24.0

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	838.10

\$134.31013431 Total Annual Cooling kWh: 2,614.87
 Total Annual Heating kWh's: 55,248.83

Heat Coil Effectiveness: 68%
 Total Annual Cooling kWh: 836.76
 Total Annual Heating kWh's: 18,075.26

Ventilation Air AH-2

BASE CASE Energy Use - Heating Only

AH-2 Flow (per dwg's) : 3,500 Hrs per Day 0.0

Fresh-Air Replacement - Sensible Heating Load

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
245,700.00	3,500	66	1	72.01

Sensible Heating Load

Q (Btu/hr)	Operating Hours
245,700.00	0.0

Annual Cost for Electric

Efficiency	HDD (66F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	7,274	66	1	0.00

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
8.19	-17.2	19	4,041	0.00

Fresh-Air Replacement - Latent Load - Dehumidification

Q (Btu/hr)	Total cfm	H1	H2	Q (kW)
	3,500	0.0138	0.0085	0.00

Latent Load - Dehumidification

Q (Btu/hr)	Operating Hours
0.00	0.0

Annual Cost for Chiller

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	0.00

Fresh-Air Replacement

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
	3,500	72	83	0.00

Cooling Load

Q (Btu/hr)	Operating Hours
0.00	0.0

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	0.00

Total Annual Cooling kWh: 0.00
Total Annual Heating kWh's: 0.00

Proposed Energy Use - Replace Unit with VRV HP & ERV

New OA Flow Rate: 200 200 Hrs per Day 24.0

Fresh-Air Replacement - Sensible Heating Capacity

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
14,040.00	200	66	1	4.11

Sensible Heating Load

Q (Btu/hr)	Operating Hours
14,040.00	24.0

Annual Cost for Electric

Efficiency	HDD (66F)	Temp In. (F)	Temp Out (F)	Annual kWh's
100.0%	7,274	66	1	11,051.10

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	HDD (≤18.9C)	Annual kWh
8.19	-17.2	19	4,041	4,604.07

0.771428571 kW of HP

Fresh-Air Replacement - Latent Load - Dehumidification

Q (Btu/hr)	Total cfm	H1	H2	Q (kW)
52,535.30	2,048	0.0138	0.0085	15.40

Latent Load - Dehumidification

Q (Btu/hr)	Operating Hours
52,535.30	24.0

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	1,516.18

4.490196239 kW of Heat Pump

Fresh-Air Replacement

Q (Btu/hr)	Total cfm	Temp In. (F)	Temp Out. (F)	Q (kW)
24,780.80	2,048	72	83	7.26

Cooling Load

Q (Btu/hr)	Operating Hours
24,780.80	24.0

Annual Cost for Heat Pump

EER	Temp In. (C)	Temp Out (C)	CDD	Annual kWh
18.60	22	28	134	715.18

\$134.31013431
Total Annual Cooling kWh: 2,231.36
Total Annual Heating kWh's: 4,604.07
Heat Coil Effectiveness: 0%
Total Annual Cooling kWh: 2,231.36
Total Annual Heating kWh's: 4,604.07

Electric Heating

BEFORE Annual Heating Cost - HUH's, CUH's Misc BB

Note: Yellow fields are editable...do not touch any blue fields.

Heater Size (Btu/hr)	204,911	<i>Note:</i> This represents the heat loss or heat requirements of the building. This calculation tool will be inaccurate if the system was initially oversized.
Heater Size (kW)	60.00	
Indoor Design Temp (°F)	72	72°F is the Standard ASHRAE Design Condition
Outdoor Design Temp (°F)	1	1°F is the Standard ASHRAE Design Condition for Halifax
Heating Degree Days	5762	Must be degree F HDD's
Operating Hours per Day	18	

Electric

Energy Content (Btu per kW-hr)	3,412	
Heat Efficiency (%)	100%	Electric Efficiency is always 100%
Annual Fuel Use (kWh)	87,722.88	
Heat Set-Back	0.00	
REVISED Annual Fuel Use (kWh)	87,722.88	

AFTER Annual Heating Cost - HUH's, CUH's Misc BB

Note: Yellow fields are editable...do not touch any blue fields.

Heater Size (Btu/hr)	204,911	<i>Note:</i> This represents the heat loss or heat requirements of the building. This calculation tool will be inaccurate if the system was initially oversized.
Heater Size (kW)	60.00	
Indoor Design Temp (°F)	72	72°F is the Standard ASHRAE Design Condition
Outdoor Design Temp (°F)	1	1°F is the Standard ASHRAE Design Condition for Halifax
Heating Degree Days	5762	Must be degree F HDD's
Operating Hours per Day	18	

Electric

Energy Content (Btu per kW-hr)	3,412	
Heat Efficiency (%)	100%	Electric Efficiency is always 100%
Annual Fuel Use (kWh)	87,722.88	
Heat Set-Back	4,443.39	
REVISED Annual Fuel Use (kWh)	83,279.49	

BEFORE Annual Heating Cost - CUH- 6

Note: Yellow fields are editable...do not touch any blue fields.

Heater Size (Btu/hr)	47,813	<i>Note:</i> This represents the heat loss or heat requirements of the building. This calculation tool will be inaccurate if the system was Just CUH-4, CUH-5, CUH-6
Heater Size (kW)	14.00	
Indoor Design Temp (°F)	72	72°F is the Standard ASHRAE Design Condition
Outdoor Design Temp (°F)	1	1°F is the Standard ASHRAE Design Condition for Halifax
Heating Degree Days	5762	Must be degree F HDD's
Operating Hours per Day	18	

Electric

Energy Content (Btu per kW-hr)	3,412
Heat Efficiency (%)	100%
Annual Fuel Use (kWh)	20,470.10
Heat Set-Back	0.00
REVISED Annual Fuel Use (kWh)	20,470.10

AFTER Annual Heating Cost - CUH-6

Note: Yellow fields are editable...do not touch any blue fields.

Heater Size (Btu/hr)	47,813	<i>Note:</i> This represents the heat loss or heat requirements of the building. This calculation tool will be inaccurate if the system was Just CUH-4, CUH-5, CUH-6
Heater Size (kW)	14.00	
Indoor Design Temp (°F)	72	72°F is the Standard ASHRAE Design Condition
Outdoor Design Temp (°F)	1	1°F is the Standard ASHRAE Design Condition for Halifax
Heating Degree Days	5762	Must be degree F HDD's
Operating Hours per Day	18	

Electric

Energy Content (Btu per kW-hr)	3,412
Heat Efficiency (%)	240%
Annual Fuel Use (kWh)	8,529.21
Heat Set-Back	0.00
REVISED Annual Fuel Use (kWh)	8,529.21

Heat Set-Back - AFTER

BB Heaters, CUH's and HUH's in Common Areas

Building Heat Loss Reduction by Lowering Space Temperature

Degree Days below 16° C (DDh)	3200.89	
No of Months with Monthly Mean Temperature below 15° C	8	
No. of Days in Heating Season	243.2	days
Fuel Type	Electric	
Recorded Annual Fuel Consumption	87,723	kWh
% of Annual Consumption for HVAC	100%	
Annual Fuel Consumption for HVAC	87,723	kWh
Annual Fuel Consumption per DDh	27	kWh per DDh
Original Space Temperature (T1)	22	°C
Reduced Space Temperature (T2)	20	°C
Hour per Day at Reduced Temperatures	8	hrs
Reduction in Heating Degree Days	162.1333333	DDh
Annual kWh Savings	4,443.39	kWh

Mini-Split HP

Current Energy Use

MS-1 - Lounge Mini-Split

Cooling Load

Q (Btu/hr)	Operating Hours
15,000.00	24.00

Peak kW
1.52

Annual Cost

IEER	Temp In. (C)	Temp Out (C)	CDD (Above 16C)	Annual kWh	Set-Back Annual kWh
18.60	20	28	400	967.74	0.00

Heating Load - Heat Pump

Q (Btu/hr)	Operating Hours
18,000.00	18.00

Revised Annual kWh
967.74

Annual Cost

EER	Temp Out. (C)	Temp In. (C)	HDD (Below 16C)	Annual kWh	Set-Back Annual kWh
9.90	-17.2	21	3,201	2,740.74	0.00

Revised Annual kWh
2,740.74

Qty.2 - Total kWh	7,416.96
Qty.2 - Total Peak kW	3.03

Heating & Dehumidification Costs due to Evaporation from Swimming Pools

INPUT
OUTPUT

Yellow = input, Blue=results, Green = Info Only
Pass mouse over cells of base case to view comments

Water Surface Area (ft2)	415	Cost Conversion	\$0.1477 \$/kWh
Cost of heating fuel (\$/MMBtu)	\$43.29		\$43.29 \$/MMBtu
Cost of dehumidification fuel (\$/kWh)	\$0.1477		

Pass mouse over cells of base case to view comments
No password for protection

	Base	ECM-1	ECM-1b	ECM-2
Description				
Water temperature (oF)	90	88	88	88
Room air temperature (oF)	83	85	85	85
Room relative humidity (%)	60%	60%	60%	60%
Average number of people in pool	4	4	4	4
Hours per year uncovered	8760	8760	8760	8760
Cost of heating fuel (\$/MMBtu)	43.29	43.29	43.29	43.29
Cost of dehumidification fuel (\$/kWh)	\$0.1477	\$0.1477	\$0.1477	\$0.1477
Occupied Time (% of uncovered hours)	20%	20%	20%	20%
Efficiency or COP of water heater	1.00	1.00	1.00	1.00
Is there dehumidification?	Yes	Yes	Yes	Yes
Efficiency or COP of dehumidification	2.50	2.50	2.50	2.50
% Latent Heat Recovery (ht pmp dehum)	70%	70%	70%	70%
Other losses as a percent of total	15%	15%	10%	10%

(Will be rounded to nearest 10%)

CASE 1:

Water temperature (oF)	88
Room air temperature (oF)	85
Room relative humidity (%)	0.6
Average number of people in pool	4
Hours per year uncovered	8760
Cost of heating fuel (\$/MMBtu)	43.29
Cost of dehumidification fuel (\$/kWh)	0.1477
Occupied Time (% of uncovered hours)	0.2
Efficiency or COP of water heater	1
Is there dehumidification? Yes	
Efficiency or COP of dehumidification	2.5
% Latent Heat Recovery (ht pmp dehum)	0.7
Other losses as a percent of total	0.15

HEATING AND DEHUMIDIFICATION DUE TO EVAPORATION FROM POOL SURFACE

Case	Indoor Temp oF	Indoor RH %	Water Temp oF	Heating Use MMBtu/yr	Heating Use \$/yr	Dehumidification Use kWh/yr	Dehumidification Use \$/yr	Heating Savings MMBtu/yr	Heating Savings \$/yr	Dehumidification Savings kWh/yr	Dehumidification Savings \$/yr	Total Savings \$/yr
Base	83	60%	90	95	\$4,116	17,273	\$2,551	--	--	--	--	--
ECM-1 - New Setpoints	85	60%	88	69	\$2,983	12,518	\$1,849	26	\$1,133	4755	\$702	\$1,835 28%
ECM-1b - Better Control by BAS (Purge with OA)	85	60%	88	63	\$2,725	13,254	\$1,958	32	\$1,391	4019	\$594	\$1,985 23%

If you get a divide by zero error for dehumidification, enter a non-zero efficiency.

MMBtu/yr	95	MMBtu/yr	69	MMBtu/yr	63
eGJ	100	eGJ	73	eGJ	66
kWh	27867	kWh	20195	kWh	18450
\$	\$4,115.90	\$	\$2,982.83	\$	\$2,725.06

VRV Cooling IDU's

NEW Current Energy Use for ECM-4 (CU)



Cooling Load

Q (Btu/hr) 40,084.00	Operating Hours 24.00	Peak kW 2.17
--------------------------------	---------------------------------	------------------------

Annual Cost

IEER 18.50	Temp In. (C) 22	Temp Out (C) 28	CDD (Above 16C) 400	Annual kWh 3,466.72	Set-Back Annual kWh 0.00
----------------------	---------------------------	---------------------------	-------------------------------	-------------------------------	------------------------------------

Revised Annual kWh 3,466.72

Portable Dehum

Portable Dehum Unit

Motor

Single-Phase

% EF	PF	Volts	Amps	hp	kW	Run Hours	kWh
100%	0.87	115	5.10	0.684	0.510	1,500	1,026

QTY.:	3
Total kWh:	3,077.95
Total Peak kW:	1.53

Elevator

Qty.2 - 31.3-hp Motors

3-Phase

% EF	PF	Volts	Amps	hp	kW	Run Hours	kWh
90%	0.85	575	31.00	31.623	26.212	1,460	46,169

NOTE: Assume 4-hrs per day total run time (not per motor)